

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 666

DATE:- 06/10/26

It is certified that an inspection team headed by DMO G.B Nagar from CMO Office inspected the GSB INTERNATIONAL SCHOOL, KAMBUXPUR DERIN, NOIDA SECTOR 151A, Gautam Buddha Nagar, on 05-10-2026 and on the basis of Water Test Report (Attached) Report No-W-280926-22 date- 01-10-2026, **Office Of The Chief Medical Officer, G.B. Nagar.** Certified that the **GSB INTERNATIONAL SCHOOL**, has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T.Govt.

This certificate is valid for One Year.

Signature with Seal:
Name : Dr Madan Mohan Mani Tripathi
Designation :
Name & Address of the Office/Department :
CMO Office Sector-39 G.B. Nagar

मुख्य चिकित्सा अधिकारी
गौतम बुद्ध नगर

To
The Principal
GSB INTERNATIONAL SCHOOL
KAMBUXPUR DERIN, NOIDA SECTOR 151A
Gautam Budh Nagar



ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)
(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)
Website: www.itslab.in, Email: itrlclab@gmail.com, info@itslab.in, contact@itslab.in
+91 9911659800, 9305780312, 09958849764



Doc. No. – ITS/7.8-01, Page No. – 1 of 1

TEST REPORT

Water Sample Analysis

Report Code-W-280926-22

Issue Date: 01/10/2026

Issued To: M/S. GSB INTERNATIONAL SCHOOL

Add: SEC-151-A Noida (G.B. Nagar) U.P-201301

SAMPLING & ANALYSIS DATA

Sample Description : Drinking Water Sample
Source of Water : R.O. Water
Sample Drawn On : 28/09/2026
Sample Drawn By : Mr. Gopal Kumar (ITS LAB Representative)
Sampling Plan & Procedure : IS:17614 (Part-1):2021
Sample Quantity : 2.0 Liter in Pet Bottle & 500 ml Glass Sterilized Bottle
Weather Condition : Clear
Sample Received On : 28/09/2026
Analysis Duration : 28/09/2026 To 01/10/2026
Test Specification To Be Used : IS:10500:2012

ANALYSIS TEST RESULTS

Chemical Analysis

S. No.	Parameter	Test Method	Results	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	pH Value @ 25°C	IS:3025(Part-11)	6.66	6.5 – 8.5	-
2.	Colour (Hazen)	IS:3025(Part-04)	< 5	5	15
3.	Odour	IS:3025(Part-05)	Agreeable	Agreeable	Agreeable
4.	Taste	IS:3025(Part-08)	Agreeable	Agreeable	-
5.	Turbidity (NTU)	IS:3025(Part-10)	< 1	1	5
6.	Total Hardness (as CaCO ₃) (mg/l)	IS:3025(Part-21)	56.0	200	600
7.	Chloride(as Cl) (mg/l)	IS:3025(Part-32)	24.9	250	1000
8.	Calcium (as Ca) (mg/l)	IS:3025(Part-40)	10.4	75	200
9.	Total Iron (as Fe) (mg/l)	IS:3025(Part-53)	<0.05	1.0	-
10.	Nitrate (as NO ₃) (mg/l)	IS:3025(Part-34)	<0.1	45	No Relaxation
11.	Total Dissolved Solid (TDS) (mg/l)	IS:3025(Part-16)	98	500	2000
12.	Alkalinity (as CaCO ₃) (mg/l)	IS:3025(Part-23)	10.0	200	600
13.	Fluoride (as F) (mg/l)	IS:3025(Part-60)	<0.1	1.0	1.5
14.	Sulphate (as SO ₄) (mg/l)	IS:3025(Part-24)	<1.0	200	400
15.	Magnesium (as Mg) (mg/l)	IS:3025(Part-46)	7.29	30	100

Microbiological Analysis

RESULTS

S.No.	Parameter	Test Method	Results	Required as per IS-10500:2012
1.	Escherichia coli	IS-15185:2016	Absent	Absent/100ml
2.	Coliform Bacteria	IS-15185:2016	Absent	Absent/100ml

Remarks: Based on above tested parameter, Water sample meets as per IS-10500:2012 in specification.
Hence water is fit for Drinking purpose

Note: - Report shall not be produce except in full without approval of the laboratory

Reviewed by
Babita Darwal
(Microbiologist)



Terms & Conditions

1. Test reports are valid only for the samples tested in our laboratory. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.

End of Report